

EMERGENCY LIGHTING PERIODIC INSPECTION AND TESTING CERTIFICATE

Certificate Reference:

1 DETAILS OF THE CLIENT

Client:

Address:

2 DETAILS OF THE EMERGENCY LIGHTING INSTALLATION

Installation Address:

Extent of the emergency lighting installation covered by this certificate:

3 DETAILS OF DEVIATIONS FROM THE CURRENT STANDARDS

Clause number	Details of Deviations

4 RELATED REFERENCE DOCUMENTS

Related reference documents and certificate numbers:

5 NEXT INSPECTION

We RECOMMEND that this installation is further inspected and tested after an interval of not more than:

Interval in accordance with Clause 7.2 of BS EN 50172: 2004 / BS 5266-8: 2004

6 CERTIFICATION OF THE INSPECTION AND TESTING

I/we hereby certify that the emergency lighting system installation at the above premises has been inspected and tested by me/us in accordance with the results of the items inspected and tested on page 2, and to the best of my/our knowledge and belief, the installation complies at the time of my/our inspection and testing with the appropriate recommendations and requirements given in BS 5266-1: 2016 Emergency lighting Part 1: Code of practice for the emergency lighting of premises, BS 1838: 2013 Lighting applications - Emergency lighting and BS EN 50172: 2004 / BS 5266-8: 2004 Emergency escape lighting systems, except for the deviations recorded.

Name:

Position:

Signature:

Date:

7 DETAILS OF THE ELECTRICAL CONTRACTOR

Trading Title:

Address:

Registration Number (if applicable):

Telephone Number:

Postcode:

8 PURPOSE OF INSTALLED EMERGENCY LIGHTING SYSTEM			
<input type="checkbox"/>	Emergency escape lighting	<input type="checkbox"/>	Standby lighting
<input type="checkbox"/>	Emergency safety lighting	<input type="checkbox"/>	Partial standby lighting
<input type="checkbox"/>	Open area lighting	<input type="checkbox"/>	High risk task area lighting

9 EMERGENCY LIGHTING INSTALLATION ARRANGEMENT			
<input type="checkbox"/>	Self-contained emergency luminaire	<input type="checkbox"/>	Combined emergency luminaire
<input type="checkbox"/>	Central battery system	<input type="checkbox"/>	Standby generator system

10 CATEGORIES OF OPERATION FOR EMERGENCY LIGHTING SYSTEM			
Type	Mode	Facilities	Duration

11 RESULTS OF INSPECTION AND TESTING		System Conforms
BS 5266-1:2016 clause reference	Requirements	
4.2	Plans are available and correct	
5.2.5; 5.2.6	Adequate illumination is provided under test conditions for safe movement on escape routes and open areas (This can be checked by visual inspection and checked that the illumination from the luminaires is not obscured and that minimum design spacings have been met)	
4.2; 5.2.8	Luminaires correctly positioned and orientated as shown on the plans	
11	Original design still valid	
5.3.3	All escape route safety signs and other safety signs such as fire fighting equipment location signs visible with the normal lighting extinguished	
5.2.8	Correct application and siting of emergency escape lighting	
7.4	Luminaires conform to BS EN 60598-2-22	
6.7	Luminaires have an appropriate Ingress Protection rating for their location	
8	Wiring systems comply with the requirements of BS 7671	
8.2	Fire protection of central wiring systems satisfactory (including cable supports)	
8.2.6	Escape lighting circuits correctly segregated from other supplies	
8.2.12	Wiring to emergency lighting supply power sources in a fixed installation, where a specialist plug and socket arrangement is used, is protected against unauthorised interference	
8.3.3	A sufficient number of suitably located test facilities are provided	
8.3.5	Central power system output voltage range is compatible with the supply voltage range of the luminaires, taking into account supply cable voltage drop	
10.6	Instructions for operation and maintenance are available	
11	Test records in the log book complete and satisfactory	
10.6; 10.7; 11	Instructions together with a suitable log book showing a satisfactory commissioning test available for use by the building occupier	
12	Luminaires tested and found to operate for their full rated duration	
12	Luminaires clean and undamaged with lamps in good condition	
10.7; 13	Building occupier and their staff trained on suitable maintenance, testing and operating procedures, or a current maintenance contract is in place	
13.3.2	Evidence of servicing of Central Battery System (in line with manufacturer's procedures); in-house or current maintenance contract is in place	
13.3.3	Evidence of servicing of Standby Generator System (in line with manufacturer's procedures); in-house or current maintenance contract is in place	
12	After test, each luminaire charging indicator operates correctly	

12 TEST INSTRUMENTS USED			
Instrument 1 (Light Meter) Model:	Serial Number:	Instrument 2 (If Any) Model:	Serial Number: